



**Municipal Office,  
Neyyattinkara.**

No : H2/8384/2023

Date : 20.05.2023

**CERTIFICATE**

Certified that the building bearing No. NMC 26/282 which houses the Viswabharathy Public School, Neyyattinkara has provided with adequate sanitation facilities and also provides the children with sufficient drinking water facilities.

This Certificate is issued to produce before the C.B.S.E. Authorities.

To  
The Manager  
Viswabharathy Public School  
Neyyattinkara.



Municipal Secretary  
Neyyattinkara

Manager  
Viswabharathy Public School  
Neyyattinkara, Thiruvananthapuram



G.P. SUJA  
PRINCIPAL  
VISWABHARATHY PUBLIC SCHOOL  
NEYYATTINKARA



**GOVERNMENT OF KERALA**

Government Analyst's Laboratory  
Commissionerate of Food Safety  
Department of Health and Family Welfare  
Thiruvananthapuram, Dated: 16.05.22  
Ph: - 0471 2472 192.

No. 15267/2022-'23

**CERTIFICATE OF EXAMINATION**

Description of Sample : Well water  
Sample details : The sample received in plastic can and sterile bottle.  
Source : **Manager, Viswabharathy Public School, Neyyattinkara, Pin -695 121.**  
Date of Receipt : 04.05.2022  
Sample quantity : 2 L + 125 ml  
Date of Analysis : Started on 05.05.22 and completed on 16.05.2022.  
Physical Appearance : Clear colourless odourless liquid.

Analytical results:

Sl. No. (1)	Quantity Characteristics (2)	Name of method of test used (3)	Result (4)	Acceptable limit as per IS No. 10500:2012 (5)
1.	pH	IS 3025	6.19	6.5 to 8.5
2.	Total Dissolved Solids	IS 3025	105.94 mg/l	500.0 mg/l
3.	Total Hardness	IS 3025	52.0 mg/l	200.0 mg/l
4.	Alkalinity	IS 3025	9.68 mg/l	200.0 mg/l
5.	Iron	AOAC	0.1 mg/l	1.0 mg/l
6.	Chloride	IS 3025	35.99 mg/l	250.0 mg/l
7.	Sulphates	APHA	30.0 mg/l	200.0 mg/l
8.	Residual Free Chlorine	IS 3025	Nil	0.5 mg/l
9.	Nitrate	Lab Validated Method	20.0 mg/l	45.0 mg/l
10.	Ammonia	IS 3025	Nil	0.5 mg/l
11.	Turbidity	IS 3025	1.0 NTU	5.0 NTU
12.	Coliforms	IS : 1622 : 1981	<2 MPN/100ml	< 2 MPN/100 ml
13.	E. Coli	IS : 1622 : 1981	Absent/100 ml	Absent/100 ml

*Opinion:* വെള്ളത്തിന്റെ pH കുറവാണ്. നാലായിരം ലിറ്റർ വെള്ളത്തിന് 250 ഗ്രാം കൂടായം പ്രയോഗിക്കുക. വെള്ളം വീണ്ടും പരിശോധനയ്ക്ക് വിധേയമാക്കുക.

Note: 1. The test report relates to the tested parameters only  
2. The result related only to the tested item (as received)



Food Analyst

Manager  
Viswabharathy Public School  
Neyyattinkara, Thiruvananthapuram

G.P. SUJA  
PRINCIPAL  
VISWABHARATHY PUBLIC SCHOOL  
NEYYATTINKARA